TAMIL NADU FIRE AND RESCUE SERVICE DEPARTMENT NO OBJECTION CERTIFICATE

Licence No:24/2025

Maduravoyal Fire and Rescue Station.

R.C.No:222/V/MVL/2025

Date: 02.09.2025

Subject: Fire And Rescue Service Department – Maduravoyal

Rescue Service Station for purpose of Fire and

No Objection Certificate – reg.

Ref

: 1. G.O. No.122. School Edu (2) Dept, Date: 14.09.2004

2. G.O. No.123. School Edu (2) Dept, Date: 14.09.2004

3. The Principal, Arulmigu Meenakshi Amman Public School,

Dated:29.08.2025

Based on the Govt. order mentioned above and the requisition letter given by the ARULMIGU MEENAKSHI AMMAN PUBLIC SCHOOL at No:62, Alapakkam Main Road, Porur, Chennai – 600116. Tamil Nadu the building and premises comprises of G+3 Floor owned/occupied by Arulmigu Meenakshi Amman Public School have complied with the fire prevention and fire safety requirements in accordance with rule of State Fire Service Rules, and Inspected on 01.09.2025 in the presence of Principal and that the school is granted NOC for a period of one year subject to the conditions stated below.

The Above Premises Inspected By S.Selvan , Station Officer, Maduravoal Fire & Rescue Station On 01.09.2025

CONDITIONS

- 1. This License is valid for One year from the date of issue.
- 2. Fire Safety Systems should be maintained in good working condition.
- 3. Mock drill to be conducted periodically with the help of local fire brigade.
- 4. Any erection of permanent or temporary structure should be intimated to this Dept.
- 5. Building occupancy capacity should not be more than 4 students per Sq. meter as per The National Building Code-2005.
- 6.Periodical maintenance and care should be taken to maintain all Fire Protection Equipments
- 7.The classrooms should always be in the ground floor up to 3rd standards

8. School Safety policy-2016 National Disaster Management Authority Guidelines above one floor should be must provided Hose Reel System.

மதுரவாயல

To:

The Principal,

Arulmigu Meenaksh Amman Public

No:62, Alapakkam Main Radio 600

Porur, Chennai – 600116.

Copy: District Officer, Chennai Central District.

FIRE & RESCUE STATION MADURAVOYAL, CHENNAI-95